



Most Widely Accepted and Trusted

# ICC-ES Evaluation Report

# ESR-2413

ICC-ES | (800) 423-6587 | (562) 699-0543 | www.icc-es.org

Reissued 04/2017  
This report is subject to renewal 04/2018.

**DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION**  
**SECTION: 07 18 13—PEDESTRIAN TRAFFIC COATINGS**  
**SECTION: 07 54 00—THERMOPLASTIC MEMBRANE ROOFING**  
**SECTION: 07 54 19—POLYVINYL-CHLORIDE ROOFING**

**REPORT HOLDER:**

**SKYLINE BUILDING SYSTEMS, INC.**

**261185 WAGON WHEEL WAY  
ROCKY VIEW, ALBERTA T4A 0E2  
CANADA**

**EVALUATION SUBJECT:**

**DECTEC SELECT WALKING DECK AND ROOF MEMBRANE**



Look for the trusted marks of Conformity!

*“2014 Recipient of Prestigious Western States Seismic Policy Council (WSSPC) Award in Excellence”*



A Subsidiary of

*ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.*



# ICC-ES Evaluation Report

**ESR-2413**

Reissued April 2017

Revised February 2018

This report is subject to renewal April 2018.

[www.icc-es.org](http://www.icc-es.org) | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION**

**Section: 07 18 13—Pedestrian Traffic Coatings**

**Section: 07 54 00—Thermoplastic Membrane Roofing**

**Section: 07 54 19—Polyvinyl-Chloride Roofing**

**REPORT HOLDER:**

**SKYLINE BUILDING SYSTEMS, INC.**

**261185 WAGON WHEEL WAY**

**ROCKY VIEW, ALBERTA T4A 0E2**

**CANADA**

**(403) 277-0700**

[www.dec-tec.com](http://www.dec-tec.com)

**EVALUATION SUBJECT:**

**DECTEC SELECT WALKING DECK AND ROOF MEMBRANE**

## 1.0 EVALUATION SCOPE

**Compliance with the following codes:**

- 2015 *International Building Code*® (IBC)
- 2015 *International Residential Code*® (IRC)

**Properties evaluated:**

- Durability
- Wind uplift resistance
- Impact resistance

## 2.0 USES

The DecTec Select membrane is used as a covering in walking deck and nonclassified roof covering systems over concrete or plywood substrates.

## 3.0 DESCRIPTION

### 3.1 General:

The DecTec Select walking deck and roof covering system consists of a membrane and deck adhesive installed over a concrete or plywood substrate.

### 3.2 Membrane:

The DecTec Select membrane is a PVC membrane with an internal polyester reinforcement. The membrane is produced in a nominally 0.060-inch [60 mils (1.5 mm)] thickness and in rolls measuring 76 inches (1930 mm) wide by 100 or 600 feet (30.5 or 182.9 m) long. The membrane meets requirements for PVC roofing and

waterproofing membranes based on testing in accordance with CAN/CGSB 37.54.

### 3.3 Adhesives:

**3.3.1 DecTec WBA 100:** DecTec WBA 100 is a water-based latex adhesive for use with the DecTec Select membrane over plywood substrates. The adhesive is supplied in 2.5-gallon (9.5 L) containers and has a shelf life of one year when stored in the original container at temperatures between 40°F and 80°F (4.4°C and 26.7°C).

**3.3.2 DecTec SBA 100:** DecTec SBA 100 is a solvent-based adhesive for use with the DecTec Select membrane over concrete or plywood substrates. The adhesive is supplied in 5-gallon (18.9 L) and 1-gallon (3.78 L) containers, and has a shelf life of one year when stored in the original container at temperatures between 40°F and 80°F (4.4°C and 26.7°C).

### 3.4 Substrates:

**3.4.1 Plywood:** Minimum <sup>5</sup>/<sub>8</sub>-inch-thick (15.9 mm) exterior-grade with tongue-and-groove edges, complying with United States Department of Commerce Product Standard PS-1.

**3.4.2 Concrete:** Concrete substrates must comply with the requirements of the applicable code.

### 3.5 Impact Resistance:

The DecTec Select walking deck and roof membrane described in this report meets requirements for impact resistance based on testing in accordance with FM 4470.

## 4.0 INSTALLATION

### 4.1 General:

Installation of the DecTec Select walking deck and roof covering system must be in accordance with the report holder's published installation instructions, the applicable code and this report. The report holder's installation instructions must be available on the jobsite during application. Installation is limited to conditions where the weather is dry and the ambient air temperature is a minimum of 50°F (10°C) when using the DecTec WBA 100 adhesive or 34°F (1°C) when using the DecTec SBA 100 adhesive. Materials must not be applied if precipitation is occurring or expected.

### 4.2 Preparation of Substrates:

Substrates must be structurally sound, clean and dry, and must be sloped a minimum of <sup>1</sup>/<sub>4</sub> inch per foot (2 percent slope).

**4.2.1 Plywood:** Plywood must be applied to framing in accordance with the requirements of the applicable code. All unsupported edges must be blocked. All penetrations through and terminations of the sheathing must be protected with metal flashing in accordance with the requirements of the applicable code and the report holder's published installation instructions.

**4.2.2 Concrete:** Surfaces must be clean and free of standing water. All holes, joints and cracks must be pointed flush with portland cement mortar and all high spots cut or ground off to provide a smooth, even surface. Any foreign material such as paint, grease or oil must be removed by mechanical means.

**4.3 Membrane Installation:**

The membrane must be adhered to the substrate with either DecTec WBA 100 adhesive (for plywood substrates) or DecTec SBA 100 adhesive (for plywood or concrete substrate). Only an area that can be completely covered in the same day's operations is to be coated with adhesive. All seams at edges and ends are hot-air welded. The adhesive must not be applied to seams or other areas to be hot-air welded.

The WBA 100 adhesive must be applied at a rate of 0.70 gallon per 100 ft<sup>2</sup> (3.5 m<sup>2</sup> per L) to the plywood substrate in accordance with the report holder's published installation instructions.

The SBA 100 adhesive must be applied to both the substrate and the underside of the membrane in accordance with the report holder's published installation instructions. The adhesive must be applied at a rate of 1 gallon to 1.25 gallons per 100 ft<sup>2</sup> (0.4 to 0.5 L per m<sup>2</sup>) to the plywood or concrete substrate. When the adhesive is completely dry, the underside of the membrane must be coated with the adhesive at a rate of 0.50 gallon per 100 ft<sup>2</sup> (0.2 L/m<sup>2</sup>). The adhesive on the underside of the membrane must not be allowed to dry completely before the membrane is rolled onto the substrate.

**4.4 Wind Resistance:**

The allowable wind uplift pressures for the DecTec Select walking deck and roof covering membrane are noted in Table 1.

**4.5 Method of Repair**

The damaged area must be clean and dry, and all existing damaged membrane removed. The membrane must be replaced in the same manner as described in Section 4.3.

**5.0 CONDITIONS OF USE**

The DecTec Select walking deck and roof covering membrane described in this report complies with, or is a suitable alternative to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

**5.1** Installation must comply with this report, the report holder's published installation instructions and the applicable code. If there is a conflict between the installation instructions and this report, this report governs.

**5.2** The membrane must be installed only by contractors registered with Skyline Building Systems, Inc.

**5.3** The deck on which the membrane is installed must be designed to resist the design wind pressures of the applicable code.

**6.0 EVIDENCE SUBMITTED**

**6.1** Data in accordance with the ICC-ES Acceptance Criteria for Walking Decks (AC39), dated June 2017.

**6.2** Data in accordance with the ICC-ES Acceptance Criteria for Membrane Roof Covering Systems (AC75), dated July 2010 (editorially revised September 2016).

**7.0 IDENTIFICATION**

Each roll of membrane is identified with the report holder's name (Skyline Building Systems, Inc.) and address, the product name, the date of manufacture and the evaluation report number (ESR-2413).

Each container of adhesive is labeled with the report holder's name (Skyline Building Systems, Inc.) and address, the product name, the batch number keyed to the date of manufacture, and the product expiration date.

**TABLE 1—WIND UPLIFT RESISTANCE**

SYSTEM NO.	ALLOWABLE WIND UPLIFT (psf)	SUBSTRATE	MEMBRANE	ADHESIVE & APPLICATION
1	135	5/8-inch plywood	DecTec Select	DecTec WBA 100 at 0.7 gal per square to the substrate only
2	630	Structural concrete	DecTec Select	DecTec SBA 100 in a 2-sided application at 1.25 gal per square on the substrate and 0.5 gal per square on the membrane underside for a combined rate of 1.75 gal per square.

For SI: 1 inch = 25.4 mm; 1 psf = 48 Pa; 1 square = 100 ft<sup>2</sup> = 9.29 m<sup>2</sup>; 1 gallon = 3.8 L.

## ICC-ES Evaluation Report

## ESR-2413 FBC Supplement

Issued February 2018

This report is subject to renewal April 2018.

[www.icc-es.org](http://www.icc-es.org) | (800) 423-6587 | (562) 699-0543 A Subsidiary of the International Code Council®

**DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION**

**Section: 07 18 13—Pedestrian Traffic Coatings**

**Section: 07 54 00—Thermoplastic Membrane Roofing**

**Section: 07 54 19—Polyvinyl-Chloride Roofing**

### REPORT HOLDER:

**SKYLINE BUILDING SYSTEMS, INC.**

261185 WAGON WHEEL WAY

ROCKY VIEW, ALBERTA T4A 0E2

CANADA

(403) 277-0700

[www.dec-tec.com](http://www.dec-tec.com)

### EVALUATION SUBJECT:

**DECTEC SELECT WALKING DECK AND ROOF MEMBRANE**

### 1.0 REPORT PURPOSE AND SCOPE

#### Purpose:

The purpose of this evaluation report supplement is to indicate that DecTec Select Walking Deck and Roof Covering System, recognized in ICC-ES master evaluation report [ESR-2413](#), has also been evaluated for compliance with the codes noted below.

#### Applicable code edition:

- 2017 Florida Building Code—Building
- 2017 Florida Building Code—Residential

### 2.0 CONCLUSIONS

The DecTec Select Walking Deck and Roof Covering System, described in Sections 2.0 through 7.0 of the master evaluation report [ESR-2413](#), complies with the *Florida Building Code—Building* and *Florida Building Code—Residential*, provided the design and installation are in accordance with the 2015 *International Building Code*® (IBC) provisions noted in the master report.

Use of the DecTec Select Walking Deck and Roof Covering System for compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and *Florida Building Code—Residential* has not been evaluated, and is outside the scope of this supplemental report.

For products falling under Florida Rule 9N-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the master report, reissued April 2017, revised February 2018.