



### NON-REMOVAL OF DOOR, SLIDING DOOR, WINDOW DETAIL

#### **NOTES:**

1. INSTALLATION TO BE COMPLETED IN ACCORDANCE WITH DEC-TEC INSTALLATION GUIDE, REFERENCE CM001.
  2. DRAWINGS NOT TO SCALE.
  3. SKYLINE BUILDING SYSTEMS ADVOCATES FOR THE REMOVAL OF A DOOR, SLIDING DOOR, OR WINDOW AS BEST PRACTICE AND FLASH IN THE THRESHOLD PER TECHNICAL DETAIL DRAWING - TDD011 DOOR SILL DETAIL.
  4. IF THE DECISION HAS BEEN MADE TO NOT REMOVE A DOOR, SLIDING DOOR, OR WINDOW, THEN THE DETAIL IS DEEMED LESS THAN IDEAL AND THE FOLLOWING MUST BE CONSIDERED:
    - A) THE INSTALLING CONTRACTOR MUST RUN THE DEC-TEC MEMBRANE UP THE VERTICAL AND UNDER THE THRESHOLD AS HIGH AS POSSIBLE.
    - B) THE DEC-TEC MEMBRANE IS ONLY TO BE ADHERED TO A VERTICAL SURFACE WITH EITHER DEC-TEC SBA 100R OR SBA 200VC.
    - C) THE DEC-TEC MEMBRANE UNDER THE SILL THRESHOLD MUST RECEIVE AN APPLICATION OF DEC-TEC APPROVED SEALANT (TREMCO 830 OR CHEMLINK M-1).
    - D) THE SEALANT BECOMES A MAINTENANCE ITEM WHERE IT MUST BE VISUALLY INSPECTED 4 TIMES PER YEAR TO ENSURE IT IS CONTINUOUS AND NOT LIFTING AWAY FROM MEMBRANE OR SILL THRESHOLD.
  5. MIN. SLOPE 1/4":12" AWAY FROM THE BUILDING STRUCTURE.
  6. SKYLINE BUILDING SYSTEMS INC. DOES NOT ASSUME RESPONSIBILITY FOR ERRORS IN DESIGN, ENGINEERING, QUANTITIES OR DIMENSIONS. THE ARCHITECT, CONTRACTORS OR OWNER'S REPRESENTATIVE MUST VERIFY ALL DIMENSIONS, SIZES AND SUITABILITY OF DETAILS.
  7. THIS DRAWING IS THE PROPERTY OF SKYLINE BUILDING SYSTEMS INC. AND MAY NOT BE REPRODUCED WITHOUT WRITTEN CONSENT.
  8. VISIT [WWW.DEC-TEC.COM](http://WWW.DEC-TEC.COM) OR CALL 1-866-461-3914 FOR ADDITIONAL INFORMATION.
- \* MUST CONSULT LOCAL BUILDING CODE AND CONFORM TO BE COMPLIANT.